



Republic of the Philippines
Department of Health
MARGOSATUBIG REGIONAL HOSPITAL
Margosatubig, Zamboanga del Sur



(0981) 141-4419

mrh_gov@yahoo.com.ph/mrhgov@gmail.com

<http://mrh.doh.gov.ph>

Date: _____

Validity: 60 days

Minimum Technical Requirements for
DEHUMIDIFIER MACHINE

PRODUCT SPECIFICATIONS

- Extraction rate
 - 70 liters/day at 80%RH
- Room size
 - 70 – 200 m²
- Refrigerant
 - R134A
- Air flow
 - 280m³/hr
- Bucket capacity
 - 5 liters
- Humidity control range
 - 30 – 80%
- Function
 - Humidity target control
 - Continuous run function
 - Water tank full indicator
 - Temperature reading
 - Auto defrost
 - Auto shutoff
 - Triple fan speed
- Roller casters
- Hose outlet provision
- Washable filter
- Power requirement
 - 220 – 240Vac

Page | 1

PREPARED & REVIEWED BY

END USER: _____
DESIGNATION: _____

JAMES CARLTY D. LABADAN, ECE
CHAIRPERSON

KEVIN S. CATAGUE, ECE
VICE-CHAIRPERSON

JOEL L. LUNA
MEMBER

IVAN PAUL L. TANO, ECE
MEMBER

CRIS ABEL M. GUEVARRA, MPA
MEMBER

APPROVED BY:

RICHARD B. SISON, MD, MHA, FPCHA, FPSMS
Medical Center Chief II

Philhealth Accredited
REVISION: 7

FM-MCC-005

EFFECTIVITY DATE: APRIL 1, 2024



Republic of the Philippines
Department of Health
MARGOSATUBIG REGIONAL HOSPITAL
Margosatubig, Zamboanga del Sur



(0981) 141-4419

mrh_gov@yahoo.com.ph/mrhgov@gmail.com

<http://mrh.doh.gov.ph>

Date: _____

Validity: 60 days

Minimum Technical Requirements for
DEHUMIDIFIER MACHINE

STANDARD ACCESSORIES:

NOTE: accessories sets is per unit

- UPS power supply

STANDARD REQUIREMENTS UPON SUBMISSION OF BIDDING DOCUMENTS

Page | 2

- Soft copy of user manual

REQUIREMENT/S IF AWARDED THE CONTRACT

- Unit must be **BRAND NEW**.
- Manual in English Language
 - 2 copy of Operation manual (Hard copy)
 - Service manual with soft copy
- Training Program
 - for end-user on equipment's operation with certificate
 - Technical training with certificate (When necessary)
- Three (3) years warranty on parts and service after commissioning and acceptance
- Certification on the availability of spare parts for the next 5 years
- Down time of machine will be added as extension of the warranty.
- With calibration certificate (When necessary)
- Supplier must respond to a service call before 72 hours and should be onsite not more than 7 days.
- **Section V. Special Conditions of the Contract**
 - Delivery Place: Margosatubig Regional Hospital, Zamboanga del Sur
- **Section VI Schedule of Requirements**

PREPARED & REVIEWED BY

END USER: _____
DESIGNATION: _____

JAMES CARLTY D. LABADAN, ECE
CHAIRPERSON

KEVIN S. CATAGUE, ECE
VICE-CHAIRPERSON

JOEL L. LUNA
MEMBER

IVAN PAUL L. TANO, ECE
MEMBER

CRIS ABEL M. GUEVARRA, MPA
MEMBER

APPROVED BY:

RICHARD B. SISON, MD, MHA, FPCHA, FPSMS
Medical Center Chief II

Philhealth Accredited
REVISION: 7

FM-MCC-005

EFFECTIVITY DATE: APRIL 1, 2024



Republic of the Philippines
Department of Health
MARGOSATUBIG REGIONAL HOSPITAL
Margosatubig, Zamboanga del Sur



(0981) 141-4419

mrh_gov@yahoo.com.ph/mrhgov@gmail.com

<http://mrh.doh.gov.ph>

Date: _____

Validity: 60 days

Minimum Technical Requirements for
DEHUMIDIFIER MACHINE

- Completion/Delivery Period: ____ calendar days upon receipt of the Notice to Proceed including the delivery, installation, testing and commissioning, Partial delivery allowed within the completion/delivery period.

Page | 3

PREPARED & REVIEWED BY

END USER: _____
DESIGNATION: _____

JAMES CARLTY D. LABADAN, ECE
CHAIRPERSON

KEVIN S. CATAGUE, ECE
VICE-CHAIRPERSON

JOEL L. LUNA
MEMBER

IVAN PAUL L. TANO, ECE
MEMBER

CRIS ABEL M. GUEVARRA, MPA
MEMBER

APPROVED BY:

RICHARD B. SISON, MD, MHA, FPCHA, FPSMS
Medical Center Chief II

Philhealth Accredited
REVISION: 7

FM-MCC-005

EFFECTIVITY DATE: APRIL 1, 2024